



NOTES:

- A. BACKFLOW ASSEMBLY SHALL INITIALLY BE TESTED AND CERTIFIED BY DISTRICT.
- B. ALL PIPE BELOW SHALL BE WRAPPED.
- C. CONCRETE PAD TO BE 2" ABOVE GRADE UNLESS INSTALLED IN LAWN AREA WHERE IT WILL BE AT 1" ABOVE GRADE AND SLOPE TO DRAIN.
- D. PROTECTIVE ENCLOSURE FOR BACKFLOW PREVENTER ASSEMBLY SHALL BE USED AT THE DISCRETION OF THE PROPERTY OWNER.
- E. LOCATE PREVENTER ASSEMBLY AS CLOSE TO METER AS PRACTICAL AS APPROVED BY DISTRICT.
- F. PROPERTY OWNER IS REQUIRED TO HAVE THE DEVICE TESTED ANNUALLY BY A CERTIFIED TESTER, WITH A COPY OF THE RESULTS SENT TO DISTRICT.
- G. NO CONNECTION SHALL BE MADE BETWEEN METER AND BACKFLOW PREVENTER FOR ANY REASON.

LEGEND

- ① REDUCED PRESSURE PRINCIPLE DETECTION ASSEMBLY SHALL BE INCLUDED IN THE LATEST EDITION OF THE "APPROVED FOR SERVICE ISOLATION CALIFORNIA PUBLIC WATER SYSTEMS" ISSUED BY THE STATE OF CALIFORNIA, DEPARTMENT OF HEALTH SERVICES, OFFICE OF DRINKING WATER.
- ② 90° FLANGED CAST IRON ELBOW (TYP).
- ③ FLANGED DUCTILE IRON OR STEEL CML&C SPOOL. BOTH ENDS SHALL BE FLANGED.
- ④ 90° CAST IRON FLANGED ELBOW.

LEGEND ON PLANS
3" (W) (R)

REVISIONS	APPROVED	DATE	VISTA IRRIGATION DISTRICT	PATH: (TOM) HASTDDWGS1-8.DWG
			RP INSTALLATION 3" & LARGER	<i>John A. Amodeo</i> 12/2/99
				JOHN AMODEO DATE R. C. E. 31161
ACAD		6/96		STANDARD DRAWING 1-8