



**NOTES**

- A) INSTALL CATHODIC PROTECTION PER STD. DWG. 8-14
  - B) ALL WATER METER OUTLETS SHALL BE LOCATED WITHIN LANDSCAPED AREAS. PLACEMENT OF OUTLETS IN PAVED AREAS REQUIRE PRIOR APPROVAL AND SHALL BE IDENTIFIED ON THE IMPROVEMENT PLANS WITH THE SYMBOL ★
  - C) INSTALL WARNING IDENTIFICATION TAPE
  - D) SILVER SOLDER JOINTS REQUIRED
- 1 SIZE X 2" SERVICE SADDLE
  - 2 2" BRONZE CORPORATION STOP
  - 3 2" COPPER TUBING-TYPE "K"
  - 4 2" COUPLING AS REQUIRED WHEN SERVICE IS 20' OR LONGER
  - 5 2" COPPER 90 DEGREE ELL
  - 6 2" BRONZE ANGLE METER STOP WITH LOCKING
  - 7 METER BOX (SEE STD. DWG. 1-4 FOR LOCATION)  
METER BOX LOCATED IN TRAVELED WAYS, PAVED AREAS AND SIDEWALKS SHALL BE SELECTED FROM THE APPROVED MATERIAL LIST.
  - 8 3/8" ROCK ( 4" TO 6" ) DEEP

DOMESTIC (W) 2"

LEGEND ON PLANS

REVISIONS	APPROVED	DATE
UPDATED	B. SMITH	03/25/11
UPDATED	B. SMITH	04/11/13

**VISTA IRRIGATION DISTRICT**

**2" WATER SERVICE**

*Brian Smith* 3/16/16  
**BRIAN SMITH**      **DATE**  
 R.C.E. 39926

**STD. DWG. 1-2**