



NOTES

- 1 APRON, WHERE REQUIRED
- 2 DISTANCE FROM HYDRANT TO TOP OR TOE OF SLOPE, MINIMUM 3' REQUIRED.
- 3 WHERE HYDRANT IS NOT PROTECTED BY A VERTICAL FACE CURB, PROTECTIVE POSTS MAY BE REQUIRED BY DISTRICT. SEE STD. DWG. 4-3 FOR DETAILS.
- 4 HYDRANT SHALL BE LOCATED 5' FROM CURB RETURN, 5' MIN. FROM DRIVEWAY, ON PROPERTY LINE EXTENSION, OR AS SHOWN ON PLANS.

REVISIONS	APPROVED	DATE	VISTA IRRIGATION DISTRICT
UPDATED	B. SMITH	03/25/11	FIRE HYDRANT LOCATIONS
UPDATED	B. SMITH	12/10/12	
<div style="text-align: right;"> 12/10/12 BRIAN SMITH DATE <small>R.C.E. 39926</small> </div>			<div style="text-align: center;"> STD. DWG. 4-2 </div>