

- 1 PAVING OR PAVEMENT REPAIR TO BE DONE IN ACCORDANCE TO CITY OR COUNTY STANDARDS
- 2 EXCAVATE BELL HOLES AT EACH PIPE JOINT TO PERMIT PROPER ASSEMBLY AND INSPECTION OF THE ENTIRE JOINT.
- 3 UNLESS OTHERWISE SHOWN ON PLANS, COVER OVER PIPE SHALL BE 36" TO 42" OR AS DIRECTED BY THE ENGINEER.
- 4 ALL PIPE LINE TRENCHES SHALL BE EXCAVATED SO THAT THE DISTANCE BETWEEN TRENCH WALLS AT THE TOP OF PIPE SHALL BE AS SHOWN BELOW:

TRENCH WIDTH

NOMINAL PIPE INSIDE DIAMETER	MINIMUM DISTANCE	MAXIMUM DISTANCE
(4") & SMALLER	(18")	(28")
(6" & 8")	(24")	(32")
(10" & 12")	(28")	(36")
(16" THRU 36")	OD PLUS (24")	OD PLUS (36")

REVISIONS	APPROVED	DATE	VISTA IRRIGATION DISTRICT	
UPDATED	B, SMITH	03/25/11	PIPE BEDDING AND TRENCH BACKFILL	BRIAN SMITH DATE R.C.E. 39926
			FOR WATER MAINS	STD. DWG. 5-2