

TABLE 1
MORTAR COATED PIPE - NUMBER OF ANODES REQUIRED

PIPE DIAMETER	LENGTH (FEET)			
	UP TO 50	50-100	100-150	150-200
UP TO 4"	2	2	4	4
6" TO 12"	2	4	6	8
14" TO 20"	4	6	10	12
20" TO 36"	4	8	12	16

50 POUND, INGOT WEIGHT, PREPACKED STANDARD ALLOY MAGNESIUM ANODES WITH 15' MIN. SPACING.

TABLE 2
DIELECTRIC COATED PIPE - NUMBER OF ANODES REQUIRED

PIPE DIAMETER	LENGTH (FEET)			
	UP TO 50	50-100	100-150	150-200
UP TO 4"	2	2	2	4
6" TO 12"	2	2	2	4
14" TO 20"	2	2	4	4
20" TO 36"	2	4	4	6

50 POUND, INGOT WEIGHT, PREPACKED STANDARD ALLOY MAGNESIUM ANODES WITH 15' MIN. SPACING.

REVISIONS	APPROVED	DATE	VISTA IRRIGATION DISTRICT	PATH: (TOM) H:\STDDWGS\8-22.DWG	
			MAGNESIUM ANODE TABLES FOR STEEL MAINS	<i>John A. Amodeo</i> (12/1/95)	
				JOHN AMODEO R. C. E. 31161	DATE
				STANDARD DRAWING	8-22
ACAD		6/96			