



NOTES:

- 1 BASED ON 225 PSI TEST PRESSURE AND BEARING VALUES OF DRY SOIL
- 2 VALUES FROM CURVES ARE FOR TEES AND DEADENDS, I.E.; STRAIGHT LINE THRUST
 FOR 90° BEND 1.4 VALUE FROM CURVE
 FOR 45° BEND 0.8 VALUE FROM CURVE
 FOR 22 1/2° BEND; 0.4 VALUE FROM CURVE
- 3 FOR CONDITIONS NOT COVERED BY CURVES, SPECIAL THRUST BLOCKS MUST BE COMPUTED AND APPROVED

REVISIONS	APPROVED	DATE	VISTA IRRIGATION DISTRICT	PATH: (TOM) H:\STDDWGS\5-8.DWG
			THRUST BLOCK BEARING AREAS	<i>John A. Amodeo</i> 12/2/79
				JOHN AMODEO R. C. E. 31161
ACAD		6/98		STANDARD DRAWING 5-8