



**NOTES**

- A. WHEN BIDDING, PRICE NOT TO INCLUDE AIR VENT & BLOW-OFF
- B. AIR VENT REQUIRED BY HIGH POINT, SIZE TO BE DETERMINED BY SIZE OF LINE.
- C. THRUST BLOCKS MAY BE REQUIRED DUE TO FIELD CONDITIONS.
- D. CATHODIC PROTECTION ANODES AND TEST STATIONS REQUIRED AT EACH END OF CROSSING. SEE STD. DWG. 8-13
- E. 18" COVER REQUIRES MIN. 1/4" WALL THICKNESS
- F. 24" COVER REQUIRES MIN. 3/16" WALL THICKNESS
- G. GREATER THAN 24" COVER REQUIRES MIN. 1/8" WALL THICKNESS.

REVISIONS	APPROVED	DATE	VISTA IRRIGATION DISTRICT	PATH: (TOM) H:\STDDWGS\6-3.DWG
			STANDARD CROSSING (ABOVE PROPOSED OBJECT)	<i>John A. Amodeo</i> 12/2/95
				JOHN AMODEO R. C. E. 31161
ACAD		6/96		STANDARD DRAWING 6-3