



NOTES:

1. DIMENSIONS A, B AND C ARE MINIMUM WIDTHS AND ONLY APPLY TO PIPE INSTALLATIONS WITH A MAXIMUM COVER OF 36" TO TOP OF PIPE.
2. EASEMENT WIDTHS MAY INCREASE AND THE DISTRICT WILL REVIEW FOR PROJECTS REQUIRING MORE THAN 36" OF COVER TO TOP OF PIPE OR IF EASEMENTS ARE WITHIN CROSS SLOPES OF GREATER THAN 6%.
3. MAXIMUM CROSS-SLOPE @ 10%

REQUIRED EASEMENT WIDTHS			
SIZE OF PIPE	A	B	C
THRU 10"	6'	14'	10'
12" THRU 18"	7'	23'	10'
20" THRU 36"	12'	18'	20'
ABOVE 36"	DISTRICT TO REVIEW		

REVISIONS	APPROVED	DATE	VISTA IRRIGATION DISTRICT	PATH: (TOM) H:\STDDWGS\5-1.DWG
			STANDARD EASEMENT WIDTHS	<i>John A. Amodeo</i> 12/2/98
				JOHN AMODEO R. C. E. 31161
ACAD		6/96		STANDARD DRAWING 5-1