



NOTES

- A. TO BE USED ONLY WHEN 6-3 IS NOT APPROVED BY DISTRICT.
- B. CHANGES IN DESIGN TO BE APPROVED BY DISTRICT AND DETAIL TO BE SHOWN ON IMPROVEMENT PLANS.
- C. BLOW-OFF REQUIRED AT LOW POINT, SIZE TO BE DETERMINED BASED UPON SIZE OF LINE.
- D. THRUST BLOCKS MAY BE REQUIRED DUE TO FIELD CONDITIONS.
- E. CATHODIC PROTECTION ANODES AND TEST STATIONS REQUIRED AT EACH END OF CROSSING. SEE STD. DWG. 8-13
- F. WHEN BIDDING, PRICE NOT TO INCLUDE BLOW-OFF OR AIR-VENT ASSEMBLY.

REVISIONS	APPROVED	DATE	VISTA IRRIGATION DISTRICT	PATH: (TOM) H:\STDDWGS\6-2.DWG
			STANDARD CROSSING (UNDER PROPOSED OBJECT)	<i>John A. Amodeo</i> 12/2/95 JOHN AMODEO DATE
				R. C. E. 31161
ACAD		6/96		STANDARD DRAWING 6-2