



- NOTE:
1. HARDWARE QUANTITIES IN INSULATING FLANGE KIT WILL VARY BASED ON GASKET PATTERN AND PIPE SIZE.
  2. DO NOT COAT OR SPRAY INSULATING COMPONENTS WITH ANY MATERIAL EXCEPT FOR THOSE SHOWN IN DETAIL 8-11

REVISIONS	APPROVED	DATE	VISTA IRRIGATION DISTRICT	PATH: (TOM) H:\STDDWGS\8-10.DWG
			INSULATING FLANGE ASSEMBLY	<i>John A. Amodeo</i> 12/2/97
				JOHN AMODEO R. C. E. 31161
ACAD		6/96		STANDARD DRAWING 8-10